



No.F6/DFS/MS/School/SZ/2022/1860

Dated: 27/9/22

### FIRE SAFETY CERTIFICATE

Certified that the Navyug Sr. Sec. School located at Moti Bagh, New Delhi-110021, comprised of Ground + 02 upper floors was granted Fire Safety Certificate by this department vide letter no.- F6/DFS/MS/School/2019/SZ/1892 dated 01.10.2019. The school building was re-inspected by Assistant Divisional Officer (M. Road) from this department on 14.09.2022 in the presence of Mrs. Sunita Dewan (Principal) and found that the school building has deemed complied with the fire prevention and fire safety requirements in accordance with the Circular no. 262-232 Dated-17.01.2005 issued by the Directorate of Education and the building (Ground + 02 upper floor) is fit for occupancy of Group B "Educational Building" with effect from 14.09.2022 renewed for a period of three years, subject to conditions printed below.

Issued on.....at New Delhi by

(Sunil Chawdhary)  
Dy. Chief Fire Officer  
Delhi Fire Service

#### Copy to:-

1. The Principal, Navyug Sr. Sec. School located at Moti Bagh, New Delhi-110021.
2. The Fire Officer, NDMC, Palika Kendra, New Delhi-01.

#### Conditions for the validity of Fire Safety Certificate

1. All the means of escape shall be kept free of all the type of obstruction all the time.
2. All the employees shall be acquainted with the use and maintenance of all fire equipments and method of smooth and speedy safe evacuation of occupants in case of emergency.
3. All the fire fighting equipments shall be maintained in perfect working condition all the time and any lapse rendering non-functional of fire safety measures, management shall be responsible.
4. The clarification with regards electrical installation, ventilation, structure stability set back area, occupancy and constructional deviation in building etc may be got verified from the authorities concerned.
5. This Fire Safety Certificate cannot be treated in any case for regularizations of unauthorized construction unauthorized use of land if any.
6. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rule 2010. The form is available on [www.dfs.delhigovt.nic.in](http://www.dfs.delhigovt.nic.in).
7. The owner / occupier shall apply for renewal of this fire safety certificate to the Director in form [sub Rule (1) of Rule 37] along with a copy of this certificate, six months prior to its expiry.